TECHNICAL DATA REPORT

TITLE Stamford 6790 B.F.W.T.

Stamford BOILER FEED WATER TREATMENT (B.F.W.T.), when used regularly according to directions, guards against mineral scale, sludge, acidic corrosion and dissolved oxygen in process steam boilers. The result is a clean, efficient boiler that will produce dry steam over a long period of time.

Add the proper amount of B.F.W.T. full strength to your boiler return tank daily, as described in the chart below. It is advisable to add B.F.W.T. immediately following blowing down your boiler.

RECOMMENDED USAGE:

Boiler H.P.	**Oz. BFWT/Day**
8 or less	3
8-20	6
20-40	10
40-50	13
50-60	16
60-70	19
70-85	22
85-100	25
100-150	30
150-250	40
250-400	50

PHYSICAL CHARACTERISTICS

APPEARANCE: Water white liquid

ODOR: Mild

SOLUBILITY: Complete (water)

FLASH POINT: None

DENSITY: 9 pounds/gallon

12/13/16